

User input indicated by **Orange fields**

User Input	
Zoning lookup	Minimum GI Score
Res	0.5

1. Enter Development Site Area m² HERE ▶			
		22955.6	
Surface Type (see tab for detailed descriptions)	Factor	Proposed Surface Area m²	Factor Values
1. Short Lawn	0.3	3538	1061.4
2. Tall Lawn (wild, not mown)	0.5	0	0
Permeable Paving	0.3	7632	2289.6
Vegetation			0
4a. Vegetation-Shrub below 3m	0.4	1320	528
4b. Vegetation-Shrub / Hedgerow above 3m	0.5	3512	1756
4c. Vegetation-Pollinator friendly perennial planting	0.5	8241	4120.5
4d. Vegetation-Preserved hedgerow	1.2	23	27.6
Trees			0
5a. New trees	0.6	402	241.2
5b. Preserved trees	1.2	0	0
7. SuDS intervention (rain garden, bioswale)	0.6	668	400.8
Green Roof			0
9a. Green Roofs - Intensive green roof (substrate is 200-1200mm in depth)	0.7	478	334.6
9b. Green Roofs - Extensive green roof (substrate is 80-200mm in depth)	0.6	2577	1546.2
10. Green wall	0.4	0	0
11. Retained Open Water	2	0	0
12. New open water	1.5	0	0
Total Equivalent Surface Area of Greening Factors		28,391.00	

**Green Factor
Numerator**

12305.90

Minimum Required GI score	Final GI score	Result
0.5	0.54	Pass